

CERTIFICATE OF CONFORMITY

2 March 2012

Test Requirement: Performance test of Dri-Eaz DRIZAIR 1200 dehumidifier

Device ID: DRIZAIR 1200 dehumidifier, model F430, serial no 36408

Result: The water extraction rate of the unit was measured at the test conditions detailed in the table below. Water was collected over a one hour period after the test condition had stabilised for three hours.

Test condition	Vol collected in 1 hr (ml)	Vol (L)/24 hrs
20C, 60% RH	890	21.4
30C, 80% RH	2070	49.7
32.2C, 90% RH	2360	56.6

Conclusion: The DRIZAIR 1200 unit supplied exceeded its specified water extraction rate of 55L/day at the 32.2C, 90%RH test condition.

Date of Tests: 1st – 2nd Mar 2012

Equipment used: Thermotron walk-in environmental test chamber, model WP-683-THCM1-5-5, serial no. 27617. Pyrex measuring cylinder.

Test Engineer: Barry Lamb

